

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Monitoring Requirements Not Met for Rubidoux Community Services District

Our water system failed to monitor as required for drinking water standards during January 2019 and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We take a minimum of ten weekly samples for coliform bacteria throughout our water distribution system. During the first week of January 2019, there was a delay in delivering our weekly coliform samples to the lab, which resulted in three of the samples being received by the lab approximately one hour past the regulatory holding time.

What should I do?

- There is nothing you need to do at this time.
- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.
- School administrators; residential rental property owners or managers; business property owners, managers, or operators, please refer to the Secondary Notification Requirements on the second page of this notice.

What happened? What is being done?

As required by the State Water Resources Control Board Division of Drinking Water, we take a minimum of ten weekly samples for coliform bacteria throughout our water distribution system. During the first week of January 2019, there was a delay in delivering our weekly coliform samples to the lab, which resulted in three of the samples being received by the lab past the regulatory holding time. The samples were still analyzed, and they were flagged in the final lab report as being received past the regulatory holding time.

For more information, please contact Steven W. Appel at (951) 684-7580 or 3590 Rubidoux Boulevard, Jurupa Valley, CA 92509.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by Rubidoux Community Services District.

State Water System ID#: 3310044. Date distributed: May 2019.